


# Hygiene-Institut des Ruhrgebiets

Institut für Umwelthygiene und Toxikologie

Direktor: Dr. Thomas-Benjamin Seiler

Träger: Verein zur Bekämpfung der Volkskrankheiten im Ruhrkohlengebiet e.V.



HYGIENE-INSTITUT · Postfach 10 12 55 · 45812 Gelsenkirchen / GERMANY

VELOSIT GmbH & Co. KG  
Industriepark 5 – 7  
32805 HORN-BAD MEINBERG  
GERMANY

Visitor's/Parcel Address:  
Rotthauer Str. 21  
45879 Gelsenkirchen

Telephone +49 (0) 209 9242-0  
Extension +49 (0) 209 9242-270  
Telefax +49 (0) 209 9242-212  
E-Mail k.stefanski@hyg.de  
Internet www.hyg.de

Reference-No.: **K-354008-21-Sf/Lk**  
Contact person: Karin Stefanski  
Prolongation: K-318789-19-WR

Gelsenkirchen, 21.12.2021

## TEST CERTIFICATE according to the DVGW Code of Practice W 347 "hygienic requirements for cement-bound materials for drinking water supply" (status 2006-05)

**Product:** VELOSIT CW 111  
**Production Place:** VELOSIT GmbH & Co. KG, 32805 Horn-Bad Meinberg - Germany  
**Specimen:** prisms (grey)

### Test result:

The test specimen meet the requirements of the DVGW Code of Practice W 347 (status 2006-05) according to the test report-no.: **K-267098-16-WR dated 12.09.2016** for the following scopes, as far as the material is qualified technically:

Scope	Products / Components	Assessment
I	mortar lining of cast iron pipes and steel pipes	---
II	concrete pipes $\geq$ DN 300, reservoirs, cementitious coatings of reservoirs	passed
III	cement for tiles, joint filler, coating of fittings (e.g. for welding joints)	passed
IV	concrete components in protective areas of drinking water plants I, II, III	passed

This test certificate is valid beginning with the date of issue and is ending by **12.09.2026** as far as there are no changes in the formula.

The Director of the Hygiene-Institute  
on behalf of

Dr. rer. nat. Damian Pleschka  
Dept. for water hygienic material testing



The assessment was based on the assumption that the used starting substances and monomers used to manufacture the product are completely known and no other substances are present in the product. The validity of this document expires in case of modifications in the composition of the product or the processing conditions. The results and evaluations refer to the groups of test items. This document may not be published without our written permission only complete and unchanged or duplicated.

**Legal Entity:** Verein zur Bekämpfung der Volkskrankheiten im Ruhrkohlengebiet e.V., **Register:** VR 519 Local Court Gelsenkirchen (Germany); **VAT ID:** DE125018356  
**Directorate:** Prof. Dr. Jürgen Kretschmann (Head), Dr. Emanuel Grün, Dr. Dirk Waider, Joachim Löchte, Dr. Thomas-Benjamin Seiler (Executive Member)